rey. 0-/3/



United States Department of the Interior

GEOLOGICAL SURVEY RESTON, VIRGINIA 22092 REPORT OF CALIBRATION

June 1, 1978

of Aerial Mapping Camera

Camera type Wild Heerbrugg RC10	Camera serial no.	1470
Lens type Wild Universal Aviogon II	Lens serial no.	UA II 3011
Nominal focal length 153 mm	Maximum aperture	f/4
	Test aperture	£/4

Submitted by

NASA Ames Research Center

Moffett Field, California 94035

Reference: Letter dated January 20, 1978 from Mr. Thomas R. Pochari

These measurements were made on Kodak micro flat glass plates, 0.25 inch thick with spectroscopic emulsion type V-F Panchromatic, developed in D-19 at 68°F for 3 minutes with continuous agitation. These photographic plates were exposed on a multicollimator camera calibrator using a white light source rated at approximately 3500K.

I. Calibrated Focal Length: 153.193 mm

This measurement is considered accurate within 0.005 mm

II. Radial Distortion:

D for azimuth angle

$\overline{\sigma}$	C		•	
₹c	O A-C	90° A-D	180° B-D	270° B-C
μm	μm	μm	μm	μm
-1	-3	-1	- 2	1
-2	-1	-2	-2	0
. 1	-1	2	-3	4
3 .	1	5	2	6
2	0	4	-1	4
-3	- 7	1	-6	0
	μm -1 -2 1 3	μm μm -1 -3 -2 -1 1 -1 3 1 2 0	μm μm μm μm -1 -3 -1 -2 -1 -2 1 -1 2 3 1 5 2 0 4	μm μm μm μm μm -1 -3 -1 -2 -2 -1 -2 -3 3 1 5 2 2 0 4 -1

The radial distortion is measured for each of 4 radii of the focal plane separated by 90° in azimuth. To minimize plotting error due to distortion, a full least-squares solution is used to determine the calibrated focal length. $\overline{D_c}$ is the average distortion for a given field angle. Values of distortion $\overline{D_c}$ based on the calibrated focal length referred to the calibrated principal point (point of symmetry) are listed for azimuths 0°, 90°, 180°, and 270°. The radial distortion is given in micrometres and indicates the radial displacement of the image from its ideal position for the calibrated focal length. A positive value indicates a displacement away from the center of the field. These measurements are considered accurate within $\underline{}$ $\underline{}$ $\underline{}$ $\underline{}$ $\underline{}$

III. Resolving power in cycles/mm Area-weighted average resolution 57.4

Field angle:	0°	7.5°	15°	22.5°	30°	35°	40°
Radial lines	80	80	95	67	80	57	.20
Tangential lines	80	67	48	48	57	57	48

The resolving power is obtained by photographing a series of test bars and examining the resulting image with appropriate magnification to find the spatial frequency of the finest pattern in which the bars can be counted with reasonable confidence. The series of patterns has spatial frequencies from 5 to 268 cycles/mm in a geometric series having a ratio of the 4th root of 2. Radial lines are parallel to a radius from the center of the field, and tangential lines are perpendicular to a radius.

IV. Filter Parallelism

The two surfaces of the Wild 520 Pan No. 5219 filter accompanying this camera are within ten seconds of being parallel. This filter was used for the calibration.

V. Shutter Calibration


Indicated shutter speed	Effective shutter speed	Efficiency		
1/200	4.0 ms = 1/250 s	76%		
1/400	2.0 ms = 1/500 s	76%		
1/600	1.3 ms = 1/750 s	76%		
1/800	1.0 ms = 1/1000 s	76%		
1/1000	0.8 ms = 1/1250 s	76%		

The effective shutter speeds were determined with the lens at aperture f/4 The method is considered accurate within 3%. The technique used is Method I described in American National Standard PH3.48-1972.

VI. <u>Magazine Platen</u>

The platen mounted in Wild RC10 film magazine No. 1470-120 does not depart from a true plane by more than 13 µm (0.0005 in).

VII. Principal Point and Fiducial Coordinates



2 (180°)

Positions of all points are referenced to the principal point of autocollimation as origin. The diagram indicates the orientation of the reference points when the camera is viewed from the back, or a contact positive with the emulsion up. The direction-of-flight fiducial marker or data strip is to the left.

Indicated principal point, corner fiducials Indicated principal point, midside fiducials Principal point of autocollimation Calibrated principal point (point of symmetry)

X coordinate	Y coordinate				
0.014 mm	0.002 mm				
0.014	0.006				
0.0	0.0				
-0.015	-0.001				

Fiducial Marks
1
2
. 3
4
5
6
7
8 .

		· · · · · · · · · · · · · · · · · · ·
-105.974	mm	-105.991 mm
106.005		105.999
-105.982		105.999
106.005	•	-105.991
-109.983		0.009
110.005		0.003
0.019	,	109.992
0.010		-109.989

VIII. Distances Between Fiducial Marks

Corner fiducials (diagonals)

1-2 299.791 3-4 299.797 шш $\mathbf{m}\mathbf{m}$

89° 591 53" Lines joining these markers intersect at an angle of

Midside fiducials

5-6 219.988 7-8 219.981 89° 59' 58" Lines joining these markers intersect at an angle of

Corner fiducials (perimeter)

2-3 211.987 1-3 211.990 mm mm

1-4 211.980 2-4 211.989 mm mm

The method of measuring these distances is considered accurate within 0.005 mm.

STEREOMODEL FLATNESS TEST AND FILM RESOLUTION

Camera No. 1470	Len	s No.	UAg II 3011	Magazine No	1470–120
Focal length 153	3.193 mm		Maximum angle o	f field tested	40
Base-height ratio	0.6		Accuracy of det	ermination	5 um

<u>-6</u>		<u>-3</u>	
	2		•
11_	<u>-5</u>	10	Direction of flight
		:	
		-5	

Stereomodel
Test point array
(values in micrometres)

The values shown on the diagram are the average departures from flatness (at negative scale) for two computer-simulated stereomodels based on comparator measurements on contact glass (Kodak micro flat) diapositives made from Kodak 2405 film exposures.

Resolving Power, in cycles/mm Area-weighted average resolution 35.4 Film: Type 2405

Field angle:	0°	7,5°	15°	22.5°	30°	35°	40°	
Radial lines	40	40	57	40	48	40	17	
Tangential lines	40	34	28	28	34	34	34	

This report supersedes the previous calibration of this camera contained in USGS Report of Calibration No. RT-R/9, dated July 11, 1973.

William P. Tayman

Branch of Research and Design Topographic Division

(4 of 4)